

## ADDENDUM 2

### Durham Public Schools Request for Statement of Proposal (RFP) For GITHENS CHILLER

RFP # 179-2223-664-Githens\_chiller

Date: 12/8/22

---

#### ADDENDUM 2 – Questions and Answers

Q2. What are other approved vendors for pumps and the chiller for the above referenced project?

A2. Please refer to Specification Section 23 21 23 “Hydronic Pumps”, Paragraph 2.1.A.

- Manufacturers listed:
  - Armstrong Pumps
  - Bell & Gossett
  - Grundfos
  - Taco

Please refer to Specification Section 23 64 26 “Air-Cooled Chillers”, Paragraph 2.1.A.

- Manufacturers listed:
  - Daikin-McQuay (AWV/Pathfinder Series)
  - Johnson Controls/York (YCIV/YVAA Series)
  - Trane (RTAF Series)

Q3. In looking over the specifications for the above referenced project, we noticed that the Substantial completion date has the year 2022. We just want to confirm the substantial date is September 16, 2023.

A3. Please refer to Specification Section 00 31 00 “Information for Bidders”, Paragraph A-13, Substantial Completion is listed as March 8, 2024.

Please refer to Bid Form 00 41 13.02. Bid form indicates Substantial Completion as March 8, 2024.

Please refer to Addendum No 1, Pre-Bid Meeting Minutes, Item #9 which lists Substantial Completion is listed as March 8, 2024.

We have reviewed the documents and do not see where September 16, 2023 is listed as the Substantial Completion date, but none the less, the intended Substantial Completion date is March 8, 2024.

Q4.

A4.